

- 1. THE CONTRACTOR SHALL CONTACT THE INSPECTOR FOR EXACT ASSEMBLY LENGTH AND HEIGHT ABOVE THE SLAB REQUIRED FOR THE FIRE LINE MASTER METER TO BE INSTALLED BY THE CONTRACTOR TO CITY SPECIFICATIONS. ALL OTHER PIPE, FITTINGS AND APPURTENANCES SHALL BE INSTALLED BY THE CONTRACTOR.

 2. ALL THE ABOVE GROUND PIPE SHALL BE FLANGED DUCTILE IRON.

 3. DOUBLE CHECK BFP TO BE HERSEY MODEL DDC II OR APPROVED EQUAL.

FIRE LINE MASTER METER ASSEMBLY

NOT TO SCALE

